

Performance Letter for ALL 5 FGD Units

Date : 05th Jan 2021
Project : FGD for all Boilers, Phase-I & II
Supplier : SHARP Supply, Pune India

Under Phase-I & II SHARP Supply India has supplied and commissioned all FGD systems for;


1. 50TPH, HFO fired boiler
2. 50TPH, HFO fired boiler
3. 70TPH, HFO fired boiler
4. 70TPH, HFO fired boiler
5. 55TPH HFO fired boiler

under MEPCO power plant at Jeddah, KSA.

- Trials Conducted with various Chemicals and found satisfactory. SO_x level after all FDS (5 nos.) is well within permissible limit as per PME (≤ 200 ppm).
- Continuously in operation, Chimney outlet values are monitored by 3rd party.
- Test reports (trials & 3rd party) are attached as an annexure.

CONTRACTED GURANTEED EMISSION VALUES

- 200 ppm


11/01/2021

POWER PLANT ENGINEER